



NOTICE OF SANITARY SEWER OVERFLOW

Village of Pewaukee
716 Glacier Rd
Pewaukee, WI 53072

On May 18th, 2026, contractors for the glacier road utility and street reconstruction project were preparing a sanitary sewer line for reinforcement with a liner. While cleaning debris from the gravity sewer pipe, the pipe collapsed, resulting in a blockage of the sanitary sewer. This collapse allowed groundwater to enter the sanitary pipe along with the wastewater. Contractors pumped out the sanitary manhole to the storm sewer pipe to prevent a basement backup. All discharges were contained to a storm sewer pipe that was blocked with sandbags and then cleaned up with a vac truck. Containment containers were brought on site to pump the wastewater into to be disposed of until the repair could be completed.

Contractors repaired the collapsed pipe on May 19th. There is no anticipated risk to the public or the environment.

Questions can be directed to the Village of Pewaukee Utilities Operations Supervisor at 262-200-7506

Shawn Tremaine
Utility Operations Supervisor
Village of Pewaukee
stremiane@villageofpewaukeewi.gov